



Montclair, NJ 07043

ADDENDUM NO. 1

Issue Date: June 11, 2007

**Request for Proposal # 716
Richardson Hall Room 267 Renovation**

Number of Pages: 2

Date of Original Bidding Documents: May 23, 2007

INTENT: This Addendum forms a part of the Contract Documents and modifies the Original Bidding Documents and Prior Addenda, if any, as identified above. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

I. Points of Information:

1. On Drawing E100 Note #2, what type of data wire is required? How many locations, how many wires at each location, and who terminates at each end?

Response: All data outlets are to be two (2) port outlets. See Drawing E100 for data outlet quantities and locations. Contractor is responsible for providing and installing all conduits, raceways, pathways and data outlets for wiring. MSU IT Department is responsible for providing and running network wiring from the data outlets to data servers.

2. On Drawing E100 Notes #3 and #4, the electric legend calls for 20 amp outlets every 12", room #267 power plan calls for (2) 30 amp circuits, #'s 35 and 37 to service the outlets in all three rooms. If the legend is correct there would be about 120 outlets, requiring at least 12 circuits. Circuit #35 has 40' of wire mold, #37 has 80' of wire mold.

Response: Drawing E001 has been revised to clarify the description of the wire mold. Drawing E100 has been revised to clarify circuit requirements and quantity of receptacles and data outlets.

3. On Drawing E100 Note #5, there is not a spec for the card reader, who is supplying the card readers?

Response: Contractor is responsible for providing and installing card readers and electrical door strikes. New card reader to be Solitaire 950 by Kaba Ilco with mortise style or approved equal. MSU is responsible for programming the card readers.

II. Special Notice of Bid Extension:

NOT USED

III. Changes to Prior Addenda:

NOT USED

IV. Changes to Bidding Requirements:

NOT USED

V. Changes to Agreement and Other Contract Forms:

NOT USED

VI. Changes to Conditions of the Contract:

NOT USED

VII. Changes to Specifications:

NOT USED

VIII. Changes to Drawings:

Re-issue Drawings E001, E100

Please acknowledge receipt of this Addendum No. 1 via fax. The fax number is 973-655-5468.

Company Name (please print)

Date

Signature

Title

Contact Name (please print)

Distribution:

All Bidders
J. Wittner/MSU
F. Cunha/Cubellis Ecoplan
Project File

Attachments:

Drawings E001, E100