



Montclair, NJ 07043

**ADDENDUM NO. 3**

**Request for Proposal # 689**

Thursday, April 3, 2008

Number of Pages: 2

Date of Original Bidding Documents: February 13, 2008  
Date of Addendum No. 1: February 28, 2008  
Date of Addendum No. 2: March 18, 2008

**INTENT:** This Addendum forms a part of the Contract Documents and modifies the Original Bidding Documents and Prior Addenda, if any, as identified above. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

---

---

**I. Points of Information:**

1. **Question:** Are all the electrical panels being utilized for this project located in room #157?  
**Answer:** Yes, all the existing panels are in room #157.
2. **Question:** The mechanical equipment schedule shows 208 volt power requirement and is fed from existing panel # 4. Are the receptacles fed from this panel as well?  
**Answer:** The receptacles are being fed from the same panel that the existing receptacles to remain are being fed from. Electrical Contractor to trace circuits back to the existing panels, demolish to spare and re-use all available circuits in the existing panels.
3. **Question:** What panel are the lighting fixtures to be fed from? They are listed as 277 volt.  
**Answer:** The Lighting fixtures are being fed from the same panel the demolished to spare fixtures are located. Electrical Contractor to trace circuits back to the existing panels, demolish to spare and re-use all available circuits in that existing panel.
4. **Question:** Where is the existing fire alarm control panel located? Is it in room V-151 with the Notifier power panel?  
**Answer:** Refer to Addendum # 2
5. **Question:** What is the anticipated start date of this project?  
**Answer:** May –June 2008 timeframe

6. **Question:** Will any of the final finished flooring be installed by MSU?

**Answer:** Refer to Addendum # 2

**II. Special Notice of Bid Extension:**

**Bid due date and time has been extended to Thursday, April 17, 2008 at 2:00 P.M. at 855 Valley Road, Suite 112, Clifton, N.J. 07013.**

**III. Changes to Prior Addenda:**

NOT USED

**IV. Changes to Bidding Requirements:**

NOT USED

**V. Changes to Agreement and Other Contract Forms:**

NOT USED

**VI. Changes to Conditions of the Contract:**

NOT USED

**VII. Changes to Specifications:**

NOT USED

**VIII. Changes to Drawings:**

NOT USED

---

Please acknowledge receipt of this Addendum No. 3 via fax. The fax number is 973-655-5468.

\_\_\_\_\_  
Company Name (please print)

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title

\_\_\_\_\_  
Contact Name (please print)

Distribution:

All Bidders  
Henry Ornovitz – MSU D & C  
Maria Pereira - Cubellis  
Project File